

Lessons Learned from Interim Volunteer-Plant (VP) ECCS Vulnerability Assessment

Bruce Letellier

Design Safety and Risk Analysis Group Los Alamos National Laboratory

NEI PWR Sump Performance Workshop Baltimore, MD July 30-31, 2003







Overview

- Objectives of Volunteer-Plant Analysis
- Plant Description
- Sump-Screen Head Loss
- Pool Transport
- Blow Down/Wash Down Debris Transport
- Debris Generation
- Break Location
- Current Insights







Objectives of Study

- Volunteer Plant study integrates all phenomenology info and analysis methods using best available plant specific data
- Illustrates one possible implementation of the Reg Guide
- Provides NRC a detailed standard of comparison for reviewing future submittals and NEI ground rules
- May provide a template for content of plant assessments but with exaggerated detail needed for methodology insight
- Sets expectations for conservatism and application of data
- Will address all major accident scenario components BUT... will not analyze all industry conditions/configs
- 'Best Available' info will still require approximation and engineering judgment. Will improve as condition assessment and further head-loss analyses are completed







Required Plant Information

Water balance calculations

- Return flow locations and rates
- Minimum pool depths for various break scenarios
- ECCS flow rates for various break scenarios

ECCS pool geometry

- Flow velocity calculations
- Identify dead sumps that can trap debris during fill up
- Scope pool dynamics (regimes of fill up, spray return, steady-state)
- Piping layout and insulation applications by type
- Sump-screen geometry
- Plant cleanliness characterization (Latent Debris)







VP Geometry Features


- Large dry containment (133 ft diam), four loop, 'remote' sumps
- Raised steam generator compartments
 - Continual falling water sweeps compartment floor
 - Compartment opposite break cannot accept debris during fill phase
 - No damping of falling water. Momentum directed to annulus
- Two adjacent roughly equivalent sump cages (260 ft² total)
 - Very close to one steam generator compartment outlet
- Sump-screen curb (4 in)
 - Effective at stopping RMI debris unless severe piling occurs
 - Reduces effective pool depth
- Nonsubmerged vertical sump screens 4.75 ft above curb
 - Failure criteria $\sim 1/2$ pool depth above curb (ft H_2O)
- Fall height from upper level drains ~10 ft
- Spray return drains adjacent to vertical sump screens
- Reactor cavity access has curb and partial steel-plate cover







Sump Pool Plan View









Sump Cages









Sump-Screen Construction









SG Compartment Entry




- Door closed during operation by radiation safety procedure
 - Intermediate debris trap or water flow blockage?
 - Both compartment doors must block to prevent flow yet large fraction of total debris may pass through these doors
 - Comparison of compartment fill up rate may show that structural failure loads are reached before switch over







Steam Generator Compartment









Floor Drains and Curbing










Concrete Structures










Piping and Equipment Model










Ranges of Sump Flow










Head-Loss Vulnerability Assessment










Containment Pool Flow Analysis

- Fluent fill up calculation with 7400 gpm break in upper left quadrant
- CS return cascades begin to hit pool at about 90s. Difficult to compute



Volume fraction at 90 s and 0.1 m height


Velocities typical during fill up







Estimated Spray Return Cascades









Observations Regarding CFD

- Good qualitative agreement between CFD models of fill/steady-state velocities and Tank Experiments
- Ancillary sources representing containment spray return paths can dominate pool activity
- Quantitative flow maps provide access to an approximate, yet tractable estimate of transport fraction
 - Logic maps and engineering judgment will be needed to consider fractions and characteristics of debris returned to the pool via various paths
- Uncertainties in location and timing of debris entering pool limit the need for a high fidelity model of debris transport

Area > threshold velocity proportional to degradation and transport for initial uniform distribution of fill-up phase debris







Transitional Pool Flow Sequence

Event

Characteristics

Break Occurs Jet impingement, steam expansion, water to bare floor with

sheet flow directed away from break. Highest

transport velocities. Initial deposition pattern in dead

areas and sumps.

Sprays Trip Spray runoff accumulates and washdown begins, Sheet

cover complete. Sumps fill via directed flow.

Deposition pattern modified by splash zones

Max Spray Return Maximum energy in minimum pool depth (~inches). No

directed flow. Pool begins to fill. Max degradation.

Pseudostable deposition pattern develops.

Lower Sumps Full Directed flow begins to develop. Deposition pattern

modified in vicinity of sump. Suspended debris collected very quickly. Steady-state flow pattern

established.

Dead sump sheltering is only significant sequester







Key Transport Test Observations


- Cal-Sil and fiber were able to form a thin bed on a ¼-in mesh vertical screen at nominal approach velocity
- Fiber flocks that enter turbulent splash zones are effectively shredded to transportable sizes
- Individual fibers are suspended and continue to collect for many hours
- Shear forces between higher and lower pool velocity zones may be capable of slowly degrading piles of fiber flocks







Containment Airborne/Washdown Debris Transport Logic Chart










Two-Phase Debris Generation










Survey of Break Locations










Integrated Vulnerability Assessment









Required Skill Set

- Familiarity with containment
 - Visual understanding of spray and floor water flow paths
- Understanding of water levels and pump-flow rates as related to EOPs
- Competent application of BLOCKAGE or other implementation of NUREG/CR-6224 head-loss correlation
 - All plants should start by understanding current sump vulnerability
- Understanding of ZOD correlations to scope break locations
- Knowledge of applied insulation types and ability to query/manipulate electronic spatial information
 - CAD models desirable, but not critical
- Awareness of debris generation and head-loss data
 - Identify unique materials and plan for characterization







Methodology Insights

- Design/adapt screens to defeat thin-bed formation
 - Transverse bulk and inlet flows to sweep or 'self-clean' surface
 - Stacked disks, crenulated plates, etc.
 - Complex filter surface to fragment fiber layer
- Can mitigate to protect against large debris volumes
 - Reducing insulation volume
 - Increase screen area with compact high surface modifications
 - Intermediate gates at pool level
 - Divert fill-up flow towards dead sumps/cavities
- Always maximize pool depth
 - Especially important for nonsubmerged screens
 - Run sprays for breaks of all sizes?
- Special attention to cleanliness at pool level for small break/no spray
- Fill-up retention in dead sumps is perhaps the only important pooltransport reduction factor







Mitigation Strategies

Preserve Integrated Safety Plan!

- Submerge screens without compromising area
 - Utilizes full NPSH margin of mechanical pumps
- Avoid horizontal screens below grade
- Test and approve back-flush/throttle cycles to dislodge compacted debris
- Midstream debris screens to intercept steady-state flow channels
- Plant cleanliness programs
- Modification of insulation types
 - With due care not to increase resident loading
- Active mechanical sweep and collect concepts
- Innovative porous media designs on top of existing screens
- Multiple inclined screen surfaces that fall away to expose new area



